

VOC Content Test Certificate

Wednesday 13th July 2022

Supplier: Maxilam New Zealand Ltd T/As Sabre Adhesives (Level 1, 40-42 Cambridge St South, Levin, 5540, New Zealand).

Sample Description: Sabre Structural SMP 40 Extra Flex

Date Tested: June 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


<p align="center">Specifications</p> <p align="center">New Zealand Green Building Council Green Star Design & As Built V1.1-13.1.1B Green Star Interiors V1.1-12.1.1B</p>	<p align="center">Sabre Structural SMP 40 Extra Flex</p>
<p align="center">Structural Glazing Adhesive Limit: 100 grams per liter</p>	<p align="center">28 gram per Litre as VOC content per material</p>
<p align="center">Meets NZGBC for VOC Content Requirement</p>	<p align="center">Yes</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

P22050127