

VOC Content Test Certificate

Monday 16th October 2023

Supplier: Sabre Adhesives Ltd (40-42 Cambridge St South, Levin, 5510, New Zealand)

Product Description: SabreSeal FRA Intumescent Sealant.

Date Tested: 12th October 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification New Zealand Green Building Council Green Star Design & As Built V1.1-13.1.1B Green Star Interiors V1.1-12.1.1B	SabreSeal FRA Intumescent Sealant
Fire Retardant Sealants and Adhesives: 250 grams per litre	34 grams per litre as VOC content per material
<i>We hereby certify SabreSeal FRA Intumescent Sealant is below the VOC Content limits of chosen category specified by Green Star Design, New Zealand Green Building Council.</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant