

# VOC Content Test Certificate

Friday, 08<sup>th</sup> March 2019

Manufacturer: Quin Global Pty Ltd (63 Hincksman Street, Queanbeyan, NSW, 2620 Australia)

Sample Description: Sabre Grip S40

Date Tested: June 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168

Test Data:

<b>Specification</b> <b>Green Building Council of Australia Green Star</b> <b>Office Design V1 IEQ-13</b>	<b>Sabre Grip S40</b>
Multipurpose Construction Adhesive: 70 grams per Litre as VOC content material	<b>&lt;1 gram per Litre as VOC content per material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

CV190277