

VOC Content Test Certificate

Wednesday 13th July 2022

Supplier: Maxilam New Zealand Ltd T/As Sabre Adhesives (Level 1, 40-42 Cambridge St South, Levin, 5540, New Zealand).

Sample Description: Sabre Gap Filler GP

Date Tested: June 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specifications New Zealand Green Building Council Green Star Design & As Built V1.1-13.1.1B Green Star Interiors V1.1-12.1.1B	Sabre Gap Filler GP
General Purpose Adhesives and Sealants Limit: 50 grams per liter	20 gram per Litre as VOC content per material
Meets NZGBC for VOC Content Requirement	Yes



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Dr. Tuan Duong
 PhD, BE (Chem. Eng.)
 Senior Consultant



Travis Hale
 BSc (Biotechnology)
 Senior Consultant

P22050127