

# VOC Content Test Certificate

Wednesday 13<sup>th</sup> July 2022

Supplier: Maxilam New Zealand Ltd T/As Sabre Adhesives (Level 1, 40-42 Cambridge St South, Levin, 5540, New Zealand).

Sample Description: Sabre MS Facade

Date Tested: June 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

**Test Data:**

<b>Specifications</b> <b>New Zealand Green Building Council</b> <b>Green Star Design &amp; As Built V1.1-13.1.1B</b> <b>Green Star Interiors V1.1-12.1.1B</b>	<b>Sabre MS Facade</b>
<b>General Purpose Adhesives and Sealants Limit:</b> <b>50 grams per liter</b>	<b>17 gram per Litre as VOC content per material</b>
<b>Meets NZGBC for VOC Content Requirement</b>	<b>Yes</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant



Dr. Tuan Duong  
 PhD, BE (Chem. Eng.)  
 Senior Consultant



Travis Hale  
 BSc (Biotechnology)  
 Senior Consultant

**P22050127**