

Emission Test Certificate

Friday 12th July 2019

Supplier: Quin Global Pty Ltd (63 Hincksman Street, PO Box 6196, Queanbeyan, NSW, 2620)

Sample Description: Sabregrip S41 Coated on SS Sheet

Date Tested: July 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

<p align="center">Green Building Council of Australia Green Star Design & As Built v1.1 - 13.1.2B & 13.2 Green Star Interiors V1.1 - 12.1.2B</p>	<p align="center">Sabregrip S41 Coated on SS Sheet</p>
<p align="center">Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m²/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.124 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

V1907009